



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
<http://www.apragaz.com>
info@apragaz.com



NOTIFIED BODY EC DESIGN EXAMINATION CERTIFICATE In accordance with module B1 of the Pressure Equipment Directive 97/23/EC		Certificate N° 01/IT/252-4-REV 1												
Manufacturer	Name	ANAF SpA												
	Address	Via del Commercio, 4 IT - 27020 Torre d'Isola (Pavia) ITALY												
Concerned Equipment : Portable Fire Extinguishers (Powder or Water Based Stored Pressure) Type : a) PS1-X ABC according tech. design ref. 32.652A.F000.00 Rev. A & file 32.652A.9200.00 Rev. A b) PS1-XN ABC according tech. design ref. 32.654A.F000.00 Rev. A & file 32.654A.9200.00 Rev. A c) PS1-P ABC according tech. design ref. 32.659A.F000.00 Rev. A & file 32.659A.9200.00 Rev. A d) FKF according to tech. design ref. 09.550A.P000.00 Rev. A & file 09.550A.9200.00 Rev. A e) PS1-X BC according tech. design ref. 05.652A.F000.00 Rev. A & file 05.652A.9200.00 Rev. A f) PS1-XN BC according tech. design ref. 05.654A.F000.00 Rev. A & file 05.654A.9200.00 Rev. A g) PS1-P BC according tech. design ref. 05.659A.F000.00 Rev. A & file 05.659A.9200.00 Rev. A Capacities : 1 kg/l Set pressure : max. 13,98 bar (+60°C) Test pressure : 20 bar Service temperature range : min. -30°C / max. +60°C for type a) b) c) e) f) g) min. 0°C / max. +60°C for type d) The manufacturer is allowed to affix the Mark « CE 0029 » to approved equipment in the conditions described in article 15 of the Directive, only if the requirements stated in module D are fully complied with. The approval is valid until 05/11/2022 APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 97/23/EC, certifies that the design of these pressure vessels conforms to the relevant requirements of the Pressure Equipment Directive 97/23/EC on basis of the documentation and samples supplied for review and approval. <table border="0"><tr><td>Date : 30/04/2014</td><td>Name : Ch. Leplat</td><td>Position : General Manager</td></tr><tr><td>Notified body identification number :</td><td>0029</td><td>Signature</td></tr><tr><td>Notified body stamp :</td><td>APRAGAZ Belgium Inspecting Authority</td><td></td></tr><tr><td>Notified body reference :</td><td>P4434/014</td><td></td></tr></table>			Date : 30/04/2014	Name : Ch. Leplat	Position : General Manager	Notified body identification number :	0029	Signature	Notified body stamp :	APRAGAZ Belgium Inspecting Authority		Notified body reference :	P4434/014	
Date : 30/04/2014	Name : Ch. Leplat	Position : General Manager												
Notified body identification number :	0029	Signature												
Notified body stamp :	APRAGAZ Belgium Inspecting Authority													
Notified body reference :	P4434/014													